

Codified Fire Safety Requirements For Use of
“ONLY ELECTRICAL EQUIPMENT/ APPLIANCES”:

It is responsibility of owner/occupier to comply following codified requirements before actual commencement of the trade activities. Asstt. Commissioner shall ensure that trade activity is commenced only after all approvals (i.e. issuance of compliance certificate from this department and trade license).

1. Entrance, Exit shall be kept unobstructed at all the time.
2. A clear passage having one metre width from entrance to rear wall or / & exit shall be kept unobstructed at all the time.
3. The entire electric wiring shall be laid as per prevailing Electricity Act & Rules & the compliance certificate to that effect from Govt. Approved electrician / agency shall be submitted along with the application.
4. Heat , hot gases and smoke shall be disposed off in safe manner
5. No combustible storage of any kind shall be done within the radius of one meter from any electric wiring and/or electric installations.
6. No loft or mezzanine floor shall be constructed unless prior approval from competent authorities.
7. If loft is approved, the same shall only be used for storage purpose.
8. If mezzanine floor is approved, there shall be no kitchen room on the mezzanine floor. The staircase landing of mezzanine shall be towards the entrance of the premises/away from kitchen.
9. The authenticity of the existing loft/mezzanine floor shall be verified by A.E. (B&F) & report of the same shall be produced at the time of inspection for Compliance certificate, failing to which compliance certificate will not be issued.
10. All electrically operated heating equipment shall have thermostat valve / electrical / electronic control system incorporated with it.
11. All the electrical equipment shall be kept on a non-combustible platform and shall be properly earthed.
12. All the staff shall be trained about the safety aspects and the procedures to be followed in the event of any emergency and shall be trained in the use of portable fire extinguishers.
13. Owner/Occupier must appoint Fire Marshal / Fire warden /fire safety officer from amongst his employees who is acquainted with evacuation procedure. He should have designated uniform such as fluorescent jacket / Arm band, cap & badge easily identifiable by citizen/users. He should also possess a whistle to alert customers/guest in case of emergency. Owner/Occupier must ensure that Fire Marshal / Fire warden /fire safety officer is present all the time during working hours. His name/s & contact details must be submitted to this department.
14. Staff shall be well acquainted with fire-fighting equipment.
15. Luminous 'Fire Exit', 'Way to exit' sign shall be provided at suitable locations showing the direction of each exit.
16. The trade license, compliance certificate from C.F.O.'s dept. shall be always available on the premises, lay-out plan showing details about entry, exit, location of staircases (if applicable) etc., shall be displayed at the prominent place on the premises.
17. The compliance of the Fire safety measures/ requirements which is mandatory from fire safety point of view, shall indemnify and in case of default, the user is liable for prosecution.
18. Evacuation plan shall be displayed conspicuously at the prominent location.

19. At any time premises shall not be overcrowded beyond occupant load certified by Architect.

All the premises who comply all fire safety norms/ recommendations are requested to put up board at prominent location at the entry in English and Marathi stating that "This premises is fire safety compliant" and "हा परिसर अग्नि सुरक्षिततेच्या दृष्टीने परिपुर्ण आहे."

Note:-

- 1. These remarks are offered from fire risk point of view only, without prejudice to legal matters pending in the court of law, if any & are valid subject to necessary permission/clearance under section 394/390 of M.M.C. Act and other permissions by concerned ward authorities, Environment Authority, etc. as per rules applicable, are obtained from concerned departments/authority. Also the authenticity & status of the structure including loft/mezzanine floor if any & complete area of the premises shall be verified by Ward Authorities, before issuing permissions for commencement of the said activity.**
- 2. Any additional fire safety requirements if necessary, will be suggested by Inspecting officer after inspection, depending upon the type of structure, trade area & other hazard, etc.**
- 3. Fire Brigade dept. reserves the right to change/alter/add/delete the terms and condition of these fire safety remarks as per the situation permits with prior intimation to the occupier.**