

**CODIFIED FIRE SAFETY REQUIREMENTS FOR MAKING GOD/GODDESS IDOL IN TEMPORARY STRUCTURE**

1. The temporary structure shall be at least 10 ft. away from any building.
2. Approach road, internal passage, entrance / exit etc. shall be kept free from any obstructions.
3. No temporary structure shall be erected near furnace, railway line, electrical sub-station, chimney or under high tension wire or like hazard unless a safety distance of 15 m is maintained.
4. The temporary structure shall be approachable to fire engine. No part of temporary structures shall be more than 45 m away from the motorable road.
5. Display Boards en-marking 'No smoking', 'Entrance/Exit', 'Emergency Exit' and 'Escape way', etc. shall be displayed conspicuously on the premises.
6. Carpet if provided shall be properly secured to the ground, and shall be treated with fire retardant paint.
7. The materials for such constructions shall preferably be of non-combustible or fire-resistant type. The materials used for the decor shall be such that it shall not generate toxic smoke/fumes. Wherever materials of combustible nature are used these shall be treated with a fire-retardant material/paint & the certificate to that effect shall be submitted along with the self-declaration regarding compliance of the said requirements.
8. The entire electric wiring shall be laid as per prevailing Electricity Act & Rules & the compliance certificate to that effect from Govt. Approved Electrical Inspector shall be submitted along with the self-declaration regarding compliance of the said requirements.
9. Provision of emergency lighting shall be made on the premises in case of Electric power failure.
10. Wherever Diesel Generator Van is provided, it shall be at least 05 mtrs. away from the temporary structure.
11. Electric main switch board shall be installed with enclosure having fire retardant material in temporary structure and a red pilot lamp shall be provided in electric main board.
12. No part of bulbs, tube lights, flood lights, etc. shall be within 15 cms of any decorative or other combustible material in the structure.
13. A distance of not less than 4.5 m outside of any temporary structure shall be kept clear of all combustible materials or vegetation and any materials obstructing the movement. Storage of combustible materials like paper shavings, straw, flammable materials, explosives, chemicals and similar materials shall not be stored inside & near any temporary structure.
14. The painting machineries and equipment shall be earthed properly and separated from other area of temporary structure with non-combustible material.

15. The proper ventilation in painting area shall provided to avoid the accumulation of the paint.
16. The paint and thinner shall be kept in metal containers with proper lids and shall be kept on the metal racks in different lots and same shall be kept in well ventilated segregated place with proper marking.
17. One exhaust fan of suitable size shall be provided and shall be kept running during working hours.
18. Smoking, cooking, heating and use of naked flame in and around the temporary structure shall be strictly prohibited.
19. Employees / workers / staff shall have knowledge of using fire extinguishers and summoning of FIRE BRIGADE in case of emergency.
20. **FIRE FIGHTING ARRANGEMENTS: -**
  - i. Two Nos. of Water type extinguisher of 09 litres capacity & 01 no. of ABC Dry Powder type extinguisher of 06 kgs. capacity per 100 m<sup>2</sup> of floor space shall be provided in/near temporary structures evenly distributed.
  - ii. Water Provision for fire-fighting at the site in the form of drums/barrels coupled with buckets.
  - iii. Two nos. of ABC Dry Powder type extinguisher of 06 kgs. capacity having BIS certification shall be provided for each switch gear/main meter room/box.
21. Temporary erection shall be dismantled immediately after the permitted period.

**Note: -**

- I. These remarks are offered from fire risk point of view only, without prejudice to legal matters pending in the court of law, if any, and necessary permissions/clearances shall be obtained from The Commissioner of Police, Municipal Ward Authority & other concerned Authorities, as per rules applicable.
- II. MCGM/Fire Brigade dept. reserves the right to change/alter/add/delete the terms and condition of these fire safety remarks as per the situation permits.
- III. The self-certified declaration about compliance of fire safety measures shall be submitted by the applicant/organiser to the Ward Authority & it will be sole responsibility of Organiser to comply with all the fire safety measures as per the provision in Section 3(3) of Maharashtra Fire Prevention & Life Safety Measures Act-2006.